



1 **EU-TYPE EXAMINATION CERTIFICATE**

2 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

3 Certificate Number: **Sira 17ATEX9365X** Issue: **7**

4 Equipment: **Mercmaster LED Generation 3 Luminaires and Mercmaster LED Low Profile Luminaires**

5 Applicant: **Appleton Group LLC**

6 Address: **9377 West Higgins Road
Rosemont
Illinois 60018
USA**

7 This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 CSA Group Netherlands B.V., notified body number 2813 in accordance with Articles 17 and 21 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN IEC 60079-0:2018/AC:2020 EN 60079-31:2014

10 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to Specific Conditions of Use identified in the schedule to this certificate.

11 This EU-Type Examination Certificate relates only to the design and construction of the specified equipment. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment.

12 The marking of the equipment shall include the following:



II 2D

Ex tb IIIC T*°C Db * Refer to ambient range table

Refer to the Schedule for the Ambient Temperature range

Project Number 80082687

Signed: J A May

Title: Director of Operations

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.
Utrechtseweg 310,
6812 AR, Arnhem,
The Netherlands



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 17ATEX9365X
Issue 7

13 DESCRIPTION OF EQUIPMENT

Ratings:

Mercmaster LED Generation 3 Luminaires with driver:

- APMS050C135UD: Input: 120-277 VAC 50/60 Hz, 125-300 VDC
Output: 22-56 VDC at 0.45-1.35 A (50 W)
- APMS100C105UD: Input: 120-277 VAC 50/60 Hz, 125-300 VDC,
Output: 57-150 VDC at 0.45-1.05 A (100 W)
- APMS150C105UD: Input: 120-277 VAC 50/60 Hz, 125-300 VDC,
Output: 86-214 VDC at 0.45-1.05 A (150 W)

Mercmaster LED Low Profile Luminaires:

- APMS050C135UD: Input: 120-277 VAC 50/60 Hz, 125-300 VDC,
Output: 22-56 VDC at 0.45-1.35 A (50 W)

Ambient Temperature ranges:

Mercmaster LED Generation 3 Luminaires – Little Primo:

Ambient Temperature	EPL	Model Number/Max Driver Output			
		MLG*L3****BU 550 mA	MLG*L5****BU 860 mA	MLG*L7****BU* 390 mA	MLG*L9****BU 480 mA
$-40^{\circ}\text{C} \leq T_a \leq +40^{\circ}\text{C}$	EPL Gc	T4	T4	T4	T4
$-40^{\circ}\text{C} \leq T_a \leq +55^{\circ}\text{C}$		T4	T4	T4	T4
$-40^{\circ}\text{C} \leq T_a \leq +65^{\circ}\text{C}^1$		T4	T3	T4	T4
$-40^{\circ}\text{C} \leq T_a \leq +70^{\circ}\text{C}^1$		-	-	T4	-
$-40^{\circ}\text{C} \leq T_a \leq +40^{\circ}\text{C}$	EPL Db, Dc	81°C	81°C	81°C	81°C
$-40^{\circ}\text{C} \leq T_a \leq +55^{\circ}\text{C}$		88°C	88°C	88°C	88°C
$-40^{\circ}\text{C} \leq T_a \leq +65^{\circ}\text{C}^1$		94°C	94°C	94°C	94°C
$-40^{\circ}\text{C} \leq T_a \leq +70^{\circ}\text{C}^1$		-	-	99 °C	-

Mercmaster LED Generation 3 Luminaires – Big Primo:

Ambient Temperature	EPL	Model Number/Max Driver Output			
		MLG*H9****BU* 480 mA	MLG*H1****BU* 595 mA	MLG*H3****BU 720 mA	MLG*H6****BU 900 mA
$-40^{\circ}\text{C} \leq T_a \leq +40^{\circ}\text{C}$	EPL Gc	T4	T3	T3	T3
$-40^{\circ}\text{C} \leq T_a \leq +55^{\circ}\text{C}$		T3	T3	T3	T3
$-40^{\circ}\text{C} \leq T_a \leq +65^{\circ}\text{C}^1$		T3	T3	T3	T3
$-40^{\circ}\text{C} \leq T_a \leq +70^{\circ}\text{C}^1$		T3	T3	-	-
$-40^{\circ}\text{C} \leq T_a \leq +40^{\circ}\text{C}$	EPL Db, Dc	61°C	64°C	66°C	71°C
$-40^{\circ}\text{C} \leq T_a \leq +55^{\circ}\text{C}$		74°C	77°C	79°C	84°C
$-40^{\circ}\text{C} \leq T_a \leq +65^{\circ}\text{C}^1$		83°C	83°C	86°C	95°C
$-40^{\circ}\text{C} \leq T_a \leq +70^{\circ}\text{C}^1$		88 °C	88°C	-	-



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

**Sira 17ATEX9365X
Issue 7**

Mercmaster LED Generation 3 Luminaires – Big Primo (MLGX):

Ambient Temperature	EPL	Model Number/Max Driver Output	
		MLG*X1****BU 1040 mA	MLG*X5****BU 1300 mA
$-40^{\circ}\text{C} \leq T_a \leq +40^{\circ}\text{C}$	EPL Gc	T3	T3
$-40^{\circ}\text{C} \leq T_a \leq +55^{\circ}\text{C}$		T3	T3
$-40^{\circ}\text{C} \leq T_a \leq +60^{\circ}\text{C}^1$		T3	-
$-40^{\circ}\text{C} \leq T_a \leq +40^{\circ}\text{C}$	EPL Db, Dc	82°C	92
$-40^{\circ}\text{C} \leq T_a \leq +55^{\circ}\text{C}$		102°C	104°C
$-40^{\circ}\text{C} \leq T_a \leq +60^{\circ}\text{C}^1$		102°C	-

Mercmaster LED Low Profile Luminaire:

Ambient Temperature	EPL	Model Number/Max Driver Output		
		MLLED*2****BU/720 mA	MLLED*3****BU/1000 mA	MLLED*4****BU/1300 mA
$-40^{\circ}\text{C} \leq T_a \leq +40^{\circ}\text{C}$	EPL Gc	T5	T4	T4
$-40^{\circ}\text{C} \leq T_a \leq +55^{\circ}\text{C}$		T5	T4	T4
$-40^{\circ}\text{C} \leq T_a \leq +65^{\circ}\text{C}$		T4	T4	T4
$-40^{\circ}\text{C} \leq T_a \leq +40^{\circ}\text{C}$	EPL Dc	66°C	66°C	66°C
$-40^{\circ}\text{C} \leq T_a \leq +55^{\circ}\text{C}$		79°C	79°C	79°C
$-40^{\circ}\text{C} \leq T_a \leq +65^{\circ}\text{C}$		88°C	88°C	88°C

Mercmaster LED Low Profile Luminaires MLT:

Ambient Temperature	EPL	Model Number/Max Driver Output		
		MLT*L3****BU 780 mA	MLT*L4****BU 780 mA	MLT*L5****BU 780 mA
$-40^{\circ}\text{C} \leq T_a \leq +40^{\circ}\text{C}$	EPL Gc	T4	T4	T4
$-40^{\circ}\text{C} \leq T_a \leq +55^{\circ}\text{C}$		T4	T4	T4
$-40^{\circ}\text{C} \leq T_a \leq +65^{\circ}\text{C}$		T4	T4	T4
$-40^{\circ}\text{C} \leq T_a \leq +40^{\circ}\text{C}$	EPL Db, Dc	82°C	82°C	82°C
$-40^{\circ}\text{C} \leq T_a \leq +55^{\circ}\text{C}$		82°C	82°C	82°C
$-40^{\circ}\text{C} \leq T_a \leq +65^{\circ}\text{C}$		82°C	82°C	82°C

1 - For MLG*L7, MLG*L9, MLG*H9, MLG*H1, MLG*H3, MLG*H6 and MLG*X1 with voltage range of 125 VDC to 169 VDC operating temperature range is -40°C to $+55^{\circ}\text{C}$.

Mercmaster LED Generation 3 Luminaires (MLG, MLGX) and Mercmaster LED Low Profile Luminaires (MLLED, MLT) are intended to be used in Zone 2, 21 & 22 classified hazardous locations. The LED Luminaires have metallic enclosures with joints containing gaskets and are suitable for indoor & outdoor use, down light, pole mounted & stanchion applications and are designed to operate within voltages 120-277 VAC, 50/60 Hz, 125-300 VDC. They are offered with below lumen levels:



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 17ATEX9365X
Issue 7

Mercmaster LED Generation 3 Luminaires (MLG)	
Nominal Lumens	Model Number
3500	MLGL3
5500	MLGL5
7500	MLGL7
9500	MLGL9
9500	MLGH9
11,500	MLGH1
13,500	MLGH3
16,000	MLGH6
20000	MLGX1
25000	MLGX5

Mercmaster LED Low Profile Luminaires (MLLED, MLT)	
Nominal Lumens	Model Number
3000	MLLED2
4000	MLLED3
5000	MLLED4
3500	MLTL3
4500	MLTL4
5500	MLTL5

Project Model Numbers

Generation 3, Little Primo, Big Primo – MLG:

Catalogue number MLG may be followed by A, C, R, S, T or W, followed by L3, L5, L7, L9, H9, H1, H3, H6, X1 or X5, may be followed by 2, 3, 4, 5 or 6 followed by C, M, N, R or W, may be followed by D, G or P, may be followed by 1, 3, 5 or W, followed by BU, optionally may be followed by A.

Mercmaster LED Low Profile Luminaires – MLLED:

Cat. No. MLLED, may be followed by A, C, R, S, T or W, followed by 2, 3, or 4, may be followed by 2, 3, 4, 5 or 6, followed by C, N or W, may be followed by P5, D5 or G5, followed by BU.

Mercmaster LED LT Luminaires – MLT:

Cat. No. MLT, may be followed by A, C, R, S, T or W, followed by L3, L4 or L5, may be followed by 2, 3, 4, 5 or 6, followed by C, M, N, R or W, followed by D, G or P, followed by 1, 3, 4 or W, followed by BU.

Variation 1 - This variation introduced the following changes:

- i. The introduction of an additional manufacturing location: Emerson, Emerson Street No. 4, Parc Industrial Tetarom 2, Cluj Napoca, 400641, Romania, was recognized.
- ii. Assessment of minor drawing modifications, the correction of notes, which are included for clarification/correction only.

Variation 2 - This variation introduced the following changes:

- i. The introduction of an additional DC Input rating (125-169 VDC)
- ii. Minor modifications in nomenclature of the product.



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 17ATEX9365X
Issue 7

Variation 3 - This variation introduced the following changes:

- i. Following appropriate assessment to demonstrate compliance with the latest technical knowledge, the previously listed standard is replaced as follows: EN 60079-0:2012/A11:2013 is replaced by EN IEC 60079-0:2018.
- ii. Add an alternate construction for the Little Primo and Big Primo LED Luminaires to include a modified Driver Housing part and additional terminal block.
- iii. Add a new high lumen version of the Big Primo LED Luminaire by adding a second driver to the construction.
- iv. Add an external metallic visor as an optional accessory.
- v. Add an alternate supplier of LED chip components (Nichia) for the 36 and 51 LED arrays.
- vi. Add 3500 K CCT and 4500 K CCT LED components.
- vii. Add high ambient temperature variants based on extrapolation.
- viii. Removal of OP IS type of protection and applicable standard EN 60079-28:2015.
- ix. Add a new high lumen version of the Mercmaster LED Low Profile luminaire (series MLT) by installing the 36 LED array already in use in the Little Primo.
- x. Recognition of minor drawing amendments, none of which affect compliance with the standards.
- xi. The description was amended to reflect the above changes.

Variation 4 - This variation introduced the following changes:

- i. The introduction of an additional manufacturing location in Saudi Arabia.
- ii. Recognition of minor drawing amendments.
- iii. Following appropriate assessment to demonstrate compliance the listed standards EN IEC 60079-0:2018 was updated to EN IEC 60079-0:2018/AC:2020 respectively with the certification coding being unchanged.

Variation 5 - This variation introduced the following change:

- i. Add two additional non-metallic materials for the clear and diffused lenses/globes used for the equipment. The two polycarbonate materials are Makrolon 2407+f1 and Makrolon 2607+f1 manufactured by Covestro.

14 DESCRIPTIVE DOCUMENTS

14.1 Drawings

Refer to Certificate Annexe.

14.2 Associated Sira Reports and Certificate History

Issue	Date	Report number	Comment
0	15 February 2018	R70138055A	The release of the prime certificate.
1	30 August 2018	N/A	Certificate re-issued to correct a typographical error in the Ambient Temperature range tables.
2	22 October 2018	R70197567A	The introduction of Variation 1.
3	08 February 2019	R70203598A	The introduction of Variation 2.
4	31 October 2019	0365	Transfer of certificate Sira 17ATEX9365X from Sira Certification Service to CSA Group Netherlands B.V.
5	03 April 2020	R80022726A	The introduction of Variation 3.
6	24 September 2020	R80041802A	The introduction of Variation 4.



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 17ATEX9365X
Issue 7

Issue	Date	Report number	Comment
7	05 August 2021	R80082687A	The introduction of Variation 5.

- 15 **SPECIFIC CONDITIONS OF USE** (denoted by X after the certificate number)
- 15.1 Mercmaster LED Series Luminaires with clear and diffused polycarbonate globes may generate ignition capable levels of electrostatic charge. When installing the equipment in a location where external conditions are conducive to the build-up of electrostatic charge on the plastic surface, the equipment shall only be cleaned with a damp cloth and the instructions in the manual followed.
- 16 **ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSRs)**
- The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.
- 17 **CONDITIONS OF MANUFACTURE**
- 17.1 The use of this certificate is subject to the Regulations Applicable to Holders of CSA Certificates.
- 17.2 Holders of EU-Type Examination Certificates are required to comply with the conformity to type requirements defined in Article 13 of Directive 2014/34/EU.