

CERTIFICATE OF COMPLIANCE

Certificate Number R-E165014
Report Reference E165014-20160517
Date 2020-December-17

Issued to: APPLETON GROUP
9377 W HIGGINS RD
ROSEMONT IL 60018 US

**This is to certify that
representative samples of**

EMERGENCY LIGHTING EQUIPMENT FITTINGS FOR
USE IN HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 844, Luminaires for Use in Hazardous (Classified)
Locations.

CSA C22.2 No. 137-M1981, Electric Luminaires for Use in
Hazardous Locations.

UL 924, Emergency Lighting and Power Equipment.

CSA C22.2 No. 141, Unit Equipment for Emergency
Lighting.


Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number R-E165014
Report Reference E165014-20160517
Date 2020-December-17

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Emergency lighting equipment fittings for use in Class I, Division 2, Groups A, B, C, and D; and Class II, Division 2, Groups F and G.

LED Housing:

Cat. No. LLED, followed by A, followed by 1 or 2, followed by 2, 5, or 7, followed by LU, followed by 2, may be followed F+, followed by H.

+ - Led Housings with suffix "F" are marked USL only, not for CNL

Optic:

Cat. No. LLED, followed by C or D, followed by PL.

The following items are intended for field installation or field replacement and are provided with instructions:

Mountings (Optional Accessories):

Cat. No. FEFBS or FEFBZ, FESBA or FESBS, FVSM, FEHBA or FEHBS, FVWFM, FERBM8Z, FEHC49Z, FEHC49S, FEHC60Z, FEHC60S.

Safety Cable (Optional Accessory):

Cat. No. LLEDSC.


Optional - "Class I, Zone 2, Group IIC";

Optional - "Zone 22, Group IIIB +"

Optional - "Type 3R, 4, 4x";

Optional - "IP66" and "IP67";

Optional - "Suitable for Wet Locations"



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

